

- Install lightning protection for sanitary lift station
- Install lightning protection for storm lift station
- Remove and replace exterior building waterproofing sealants throughout entire facility
- Replace or repair all cracked/broken brick and miscellaneous damaged plaster
- Stage Curtains - fire proofing
- Stage Curtains - safety rigging on tracks
- Safety and security review

Check out the projects for other feeder schools.

Caney Creek High School

- Capacity and program upgrades
Increase capacity and upgrade fine arts and athletics facilities to accommodate growth
- Add outlet for the water closet lift
- Add lightning protection at auditorium
- Add ground faults by sinks at baseball and practice field
- Baseball turf conversion
- Replace vent hoods
- Camera conversion - analog to IP
- Football turf conversion
- Install required exit signage
- Upgrade air conditioning for technology
- Provide district standard projector at designated rooms
- Remove and replace exterior building waterproofing sealants throughout entire facility
- Renovate serving line
- Repair or replace headwall/pipe near northwest corner of baseball at practice fields
- Replace cracked inlet grates, west side
- Replace breaker in mechanical mezzanine at gym
- Replace ceilings as necessary at storm drain repairs
- Replace mechanical room boilers
- Reseal and restripe asphalt lot on north side



Caney Creek High School (cont'd)

- Restripe teachers' parking lot
- Safety and security upgrades
- Softball turf conversion
- Stage Curtains - fire proofing
- Baseball covered batting cages
- Softball covered batting cages
- Fire alarm voice evacuation system upgrade
- DAS Repeater System and BDA First Responder
- Stage Curtains - safety rigging on tracks

Moorhead Junior High

- Install range hood over instructors cook top
- Install return air in designated areas
- Install district standard projector in designated rooms
- Install exhaust in designated room
- Remove and replace asphalt entrance and exit with concrete
- Remove and replace exterior building waterproofing sealants throughout entire facility
- Repair finishes (floor and wall) and monitor expansion joint between office and stage due to movement
- Replace existing built up roof system
- Replace or repair all cracked/broken brick and miscellaneous damaged plaster
- Replace water heater in Mechanical Room #2 and add hot water to office mop sink
- Stage Curtains - fire proofing
- Stage Curtains - safety rigging on tracks
- Safety and security review

Grangerland Intermediate

- Stage Curtains - safety, rigging & tracks
- Add outlets for personal lift
- Stage Curtian - fire proofing
- Safety and security review

